



Evaluation Listing CCMC 14128-L Floraseal 50

MasterFormat: 07 21 19.09
Evaluation issued: 2019-04-30

1. Evaluation

The product conforms to CAN/ULC-S712.1:2017, “Thermal Insulation – Light Density, Open Cell Spray Applied Semi-Rigid Polyurethane Foam – Material Specification.”

The product’s minimum site density, design thermal resistance value (RSI), water vapour permeance (WVP) and time-to-occupancy values are provided in Table 1.1.

Table 1.1 Minimum Site Density, Design RSI, WVP and Time-to-Occupancy Specifications for the Product

Property	Minimum Site Density ⁽¹⁾ (kg/m ³) [lb/ft ³]	50 mm Design RSI (m ² ·C/W)	50 mm WVP ⁽²⁾ (ng/(Pa·s·m ²))	Time-to-Occupancy ⁽³⁾ (day)
Floraseal 50	8.87 [0.55]	1.28	1296	1

Notes to Table 1.1:

- (1) Based on the qualification testing to CAN/ULC-S712.1, the specified minimum site density must comply with CAN/ULC-S712.1 as measured on site in accordance with CAN/ULC-S712.2:2017, “Standard for Thermal Insulation – Light Density, Open Cell Spray Applied Semi-Rigid Polyurethane Foam – Installation.”
- (2) The WVP is determined from a core sample with the top and bottom skins removed. Due to the effect of the skins, the WVP at this thickness may be lower in the site-installed product.
- (3) For retrofit construction, the time to occupancy is one (1) day when the segregated retrofit area is ventilated as required by CAN/ULC-S712.2 during installation of the product. See Table 1, Note 3 in the Annex for further details.

2. Description

The product is an open-cell, spray-applied, semi-rigid polyurethane foam of light density. The foam system consists of two components that must be labelled as follows, along with “CCMC 14128-L”:

- Isocyanate (Component A): “ISO A-2732”; and
- Resin (Component B): “Floraseal 50.”

The two components are mixed on-site by a SOLUTIONS Genyk Inc.-qualified installer (see Section 3.1) with fixed-ratio positive displacement equipment. The colour of the installed final cured product is yellow.

3. Standard and Regulatory Information

See the Annex appended to this Listing, which summarizes the product standard.

This/These product(s) was/were evaluated to the product standard referenced in the Annex current as of 2019-05-07. Note that the Annex may have been updated since this Listing was issued to include more recent editions of the applicable product standard. Therefore, this Listing may not reflect the requirements contained in any updated version of this product standard.

3.1 Qualified Installers

This is a site-manufactured product whereby SOLUTIONS Genyk Inc. requires that only specific, qualified installers be authorized to install its proprietary spray-polyurethane insulation in buildings. In accordance with the SOLUTIONS Genyk Inc. site quality assurance program (SQAP), the certification organization Urethane Foam Consultants, Inc. (UFC) has been commissioned to license the specified installers and issue the requisite UFC identification card to them. All specified installers must have a UFC identification card.

3.2 Third-Party Site Auditing of Qualified Installers

As part of its SQAP, SOLUTIONS Genyk Inc. also stipulates that site-audit inspections be conducted by site inspectors licensed by UFC. Upon completion of the site audit, UFC will report the product's conformity results and any corrective action required, if necessary, to SOLUTIONS Genyk Inc. Building officials who would like site-audit inspections conducted on specific building sites can contact UFC at:

Urethane Foam Consultants Inc. (UFC)
160 Main St. South, Suite 547
Brampton, ON L6W 4C1

Tel.: 905-702-2555

Listing Holder

SOLUTIONS Genyk Inc.
1701 3rd Avenue
Shawinigan, QC G9T 2W6

Tel.: 819-729-0395

Fax: 819-729-0383

Email: info@genyk.com

Web site: www.genyk.com

Site – Finished Product

The foam insulation is a site-manufactured product.

Plant – Raw Materials

Shawinigan, QC

Disclaimer

This Listing is issued by the Canadian Construction Materials Centre, a program of the Construction Research Centre at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc_index.html, or contact the Canadian Construction Materials Centre, Construction Research Centre, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone 613-993-6189. Fax 613-952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

Date modified:
2019-06-07